

WL131V LED12S		1200	П	12	PSU	EL3		55	43			1.95
			П	15	PSR	MDU / EL 3				• •	2.10	
			П	13	PSED	EL 3	_ _ 350 197					2.05
		000 / 2000	П	22	PSU	EL 3	- 350 197					1.95
WL131V LED20S	3000 / 4000		П	25	PSR	MDU / EL 3					•	2.10
LED205 4000		П	23	PSED	EL 3						2.05	
			П	36	PSU	NA		84	43			3.05
WL131V LED34S		3400	П	38	PSR	MDU/EL3	480 283				3.30	
LED345			11	37	PSED	EL 3						3.25



0000 000 00000 © 2018 Signify Holding. All rights reserved

_

_|

1/4



SENSITIVE - The luminaire shall be installed by a qualified electrician and wired in accordance with the latest IEE electrical regulations or the national requirements.

ATTENTION ELECTROSTATIC

- This luminaire is not suitable for use as emergency lighting.
- The light source contained in this luminaire shall only be replaced by the manufacturer or his service agent or a similar qualified person.
- For use in environments where an accumulation of conductive dust on the luminaire may be expected.
- Insulation between LV and control conducts should be basic insulation at least.





Data subject to change without notice Keep for future reference: *www.philips.com/lighting*



∫3x

2

7









2/4



HF Motion Sensor

By selecting the combination on the DIP switch, sensor data can be precisely set for each specific application.



ON		1	2	%
	1	on	on	100
	11	on	-	75
	111	-	on	50
	IV	-	-	25

Detection area. (default 100%) show patterns. Detection area can be reduced by selecting the combination on the DIP switches to fit precisely each application.

		3	4	5	Time
	I	on	on	on	5 s
ON	Ш	-	on	on	30 s
T		on	-	on	90 s
Ē	IV	-	-	on	3 min
	V	on	on	-	20 min
	VI	-	-	-	30 min

Hold time. (default 3 min.) Refers to the time period the lamp remains at 100% illumination after no motion detected.

		6	7	8	Time
	1	on	on	on	0 s
ON		-	on	on	5 s
Î		on	-	on	5 min
Ē	IV	-	-	on	10 min
	V	on	on	-	30 min
	VI	-	on	-	1 hr.
	VII	_	_	-	+∞

ON

	1	2	3	4	Lux	
I	-	-	on	on	2	-
П	-	-	-	on	5	
	-	on	on	-	10	\ \
IV	-	-	on	-	25	
V	-	on	-	-	50	
VI	on	-	-	-	100	
VII	-	-	-	-	Disable	

ON		5	6	%	
	I	on	on	50	
	П	-	on	30	
	Ш	on		20	
	IV	-	-	10	

absence of people.

3/4

Stand-by period. (default 10 min.) Refers to the time period the lamp remains at a low light level before it completely switches off in the long absence of people. When set to " ∞ " mode, the low light is maintained until motion is detected.

Daylight sensor. (default 10 lux.)

The sensor can be set to only allow the lamp to illuminate below a defined ambient brightness threshold.

When set to Disable mode, the daylight sensor will switch on the lamp when motion is detected regardless of ambient light level.

100 lux, 50 lux, 30 lux: twilight operation, 10 lux, 5 lux, 2 lux: darkness operation only.

|

Stand-by dimming level. (default 20%)

The low light level you would like to have after the hold time in the long